



NOTE:

1. CURB REVEALS SHALL BE 1/2" MAX. WHERE RAMP MEETS PAVEMENT AT ROADWAY.
2. SIDEWALK SHALL BE INSTALLED FLUSH WITH EXISTING DRIVEWAY.
3. SIDEWALK SHALL BE 6" THICK AT DRIVEWAY APRONS.
4. SEE STANDARD SIDEWALK DETAIL FOR SIDEWALK INSTALLATION.

NO SCALE



Gerald D. Jennings, Mayor
 Randall J. Milano, P.E., City Engineer

CITY OF ALBANY DIVISION OF ENGINEERING
 STANDARD DETAILS

DETAIL NAME:

DRIVEWAY/SIDEWALK DROP
 CURB DETAIL

DETAIL No.

DW-1

FILE NAME:

DW-1.DWG

DATE ISSUED

05/01/02

REVISION DATE

06/01/10